




पिंपरी चिंचवड महानगरपालिका, पिंपरी ४११०१८

नागरी सुविधा केंद्र (संगणक प्रणाली)

अर्जाची पावती / पोहोच पावती



Receipt No :- 303324250000557

दिनांक :- 04/04/2024

Challan No:- 203324250000168

अर्ज क्र :- 103324250000322

वेळ :- 02:25:51 PM

कार्यालय :- CFC33/Pimpri

विषय :- शाळा वापर अग्नी दाखला

विभाग :- अग्निशामक विभाग

साईट पत्ता :- Wakad

अर्जदाराचे नाव :- Indus Champs School

Mobile No.:-

महोदय,

आपण दिलेल्या अर्जाची नोंद आम्ही घेतली आहे. आपला अर्ज क्रमांक 103324250000322 आहे. आपण दिलेले काम अंदाजे दि. 17/04/2024 पर्यंत पूर्ण होणे अपेक्षित आहे. आपल्या अर्जावर तपासणी करून आपणांस त्याबाबत लवकरच SMS द्वारे कळविण्यात येईल. आपले प्रमाणपत्र/कागदपत्र मिळण्याचे ठिकाण CFC33/Pimpri राहिल.

र. रू. ५०० (पाचशे फक्त)



अर्जासोबत खालील कागदपत्रे स्विकारणेत आली

- 1) अग्नीशामक विभागाकडील इमारत अंतिम ना हरकत दाखला
- 2) अग्नीशामक उपक्रमाचे सुस्थितीबाबत फायर लायसिंग एजेन्सीकडील "बी" फॉर्म
- 3) मनपा चालू वर्षाचे मिळकत कर भरल्याची पावती प्रत
- 4) मनपा बांधकाम परवानगी विभागाकडील पूर्णत्वाचा दाखला व मंजूर नकाशा प्रत
- 5) अग्निशामक यंत्रणा लावले बाबतचे फोटो व C . D
- 6) प्रकरणानुसार अन्य आवश्यक कागदपत्रे
- 7) मागणी अर्ज
- 8) शाळेतील एकूण कर्मचारी वर्ग संख्या (पदनिहाय) व कामकाजाच्या वेळा
- 9) शाळेतील आपत्कालीन संबंधी किमान ०२ जबाबदार व्यक्तींचे नाव ,पदनाम व दूरध्वनी क्रमांक



पिंपरी चिंचवड महानगरपालिका
अग्निशमनविभाग
Pimpri Chinchwad Municipal Corporation
Fire Department



File No:-

621

O.W.No:- Fire/01/5RC-175/ WS 1621 /2021.

Date:- 28/10/2021

FIRE SAFETY CERTIFICATE


Token No:- 103321220002960

Token Dt:- 02/07/2021 & 13/10/2021

M/s. Indus Champs School, Pune. had applied for Fire Safety Certificate. The Fire Officer has visited the school inspected the Fire Protection System installed at site and as per his technical remarks this NOC is being issued subject to compliance of following conditions.

- 1) The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
- 2) The fire extinguishers handling and operational training to be imparted to the teaching/ non-teaching/security staff of the school.
- 3) You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-'B' Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
- 4) You will keep all the Static Water Tanks full for any fire emergency.
- 5) Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustible material.
- 7) "No Smoking Boards" "Emergency Exit" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
- 8) You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
- 9) You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
- 10) This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 11) You are not permitted to construct the school building's remaining floors in the school working hours.
- 12) LPG cylinder placed inside the chemistry lab near the flammable chemicals should be kept at a safe place outside the chemistry lab. Inspection of the LPG connection should be carried out through the concern authority and inspection certificate should be submitted next time while coming for the Fire Safety Certificate
- 13) Electrical cable duct/conduit should be provided for all the electrical cables which are hanging inside the passage area.
- 14) Regarding the safe working of all the electrical equipment in this educational building, Electrical Audit by the Hon. Electrical Inspector, Yerwada, Pune should be done before next renewal of Fire Safety Certificate.
- 15) All the repair work should be done as per the Structural Safety Audit before coming next time for the Fire Safety Certificate.
- 16) PCMC Fire Department has noticed that, You did not obtain Provisional Fire NOC and Final Fire NOC for the school building. Hence, Provisional Fire NOC and Final Fire NOC for the school building should be obtained before coming next time for the Fire Safety Certificate.
- 17) All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- 18) This School Operational (Utility) Fire NOC is issued for only "C", 2Pr.+05, "B" Gr.+03, "A" Gr.+04 Floor, The terms and condition must be strictly fulfilled mentioned in fire NOC.
- 19) This Fire NOC is valid up to Dt. 31 March 2022 only subject to undertaking letter No. 22703 Dt. 11/10/2021 (BF365240) for providing Additional External Staircase and renewal of these NOC should be done every year before above mentioned date.

To,
The Principal,
Indus Champs School,
Wakad, Pune-411057



Chief Fire Officer
Pimpri Chinchwad Municipal Corporation
Pimpri-18

(The Fire Safety Certificate Fees Rs.67,200/- paid, Receipt No.303321220016525,Dt.25/10/2021)